

(ESPLOST) Woodville-Tompkins Gym Construction & Auditorium Renovation

Number: Bid C20-12

Posting Date: 10/13/19

Addenda # 5

Addenda Posting Date: 11-07-2019

Closing Date: 11/14/2019 11:00 am

The information contained in this document shall become an official part of the original document and shall be acknowledged as noted on the Certification Form of solicitation document in the space provided. Failure to acknowledge receipt of an addendum may result in a status of non-responsive. Firms are encouraged to review the contents of this document and to respond accordingly.

Addenda No. 5 is being issued to provide the following information and clarifications.

Question: We respectfully request an extension of the Bid Date to November 21, 2019, due to conflicts on November 14, 2019.

Answer: Request Denied

Question: Substitution Request – World Dryer - Extreme Air GXT9-M

Answer: Substitution Request - Not Approved

Question: Substitution Request – Peachtree Protective Covers - Aluminum Walkway Covers

Answer: Substitution Request - Approved.

Question: Aluminum Rails – Plans call for Brushed finish.

Specification: 2.8 Aluminum Finishes

A. Mechanical Finish: AA-M12 (Mechanical Finish: nonspecular as fabricated).

B. Clear Anodic Finish: AAMA 611, AA-M12C22A42/A44, Class I, 0.018 mm or thicker.

1. Color: Clear

Which is Correct?

Answer: Finish B. is correct, however, see Addendum #4 for additional details.

Question: Stainless Steel Rails

A10.1 Does not have a Detail, Finish or Specification

Please advise as to Detail – Square, Rectangle, or Pipe Material?

Question: Stainless Steel 304? 316L

Question: Finished Required?

a. #4 (180 grit) centerless ground.

b. #4 (180 grit) directional

c. #7 mirror polish with visible grain

d. #8 mirror polish

Answer: **No Stainless Steel Railings are to be used – SEE ADDENDUM #4 for details**

*****ALL OTHER TERMS AND CONDITIONS REMAIN UNCHANGED*****

End of Addenda #5 to Bid C20-12

(ESPLOST) Woodville-Tompkins Gym Construction & Auditorium Renovation